


SECTION A-A



NOTES:

- 1) All ductwork to be manufactured to DW144 low velocity.
- 2) All dimensions are in millimetres.
- 3) All open ends to be bagged off during the installation to avoid ingress of dirt!!
- 4) All Secondary Spiral Fan Coil Unit Ductwork To Be Internally Lined With 9mm Barafoam Acoustic Lining Including The Plenum Box.

LEGEND:

- | | | |
|------|---|------------------------|
| AP | - | ACCESS PANEL |
| CE | - | CAP END |
| BE | - | BLANK END |
| SE | - | SMALL END |
| LE | - | LARGE END |
| FTT | - | FLAT TOP TAPER |
| FBT | - | FLAT BOTTOM TAPER |
| SU | - | SET UP |
| SD | - | SET DOWN |
| FD | - | FIRE DAMPER |
| SMD | - | SMOKE DAMPER |
| VCD | - | VOLUME CONTROL DAMPER |
| MVCD | - | MOTORISED VCD |
| ID | - | IRIS DAMPER |
| SBD | - | SINGLE BLADE DAMPER |
| FTC | - | FLAT TOP CONNECTION |
| FBC | - | FLAT BOTTOM CONNECTION |
| CTS | - | CUT TO SUIT |
| REF | - | REFERENCE POINT |

A	28-11-2018	Fan Coil Unit Heights And Heights Of Grilles Raised To Maximum Achievable. Off Sets Added To FCU 1.1 Due To Downstand Beam.
---	------------	---

Rev	Date	Description
-----	------	-------------

AVEAT HEATING LTD

MECHANICAL, ELECTRICAL,
PLUMBING & HEATING ENGINEERS

Lambert House, Driberg Way,
Braintree, Essex, CM7 7NB

TEL: (01376) 341653/325670
FAX: (01376) 551210

Project:

Olwen House
8-20 Loman Street
London
SE1 0HE

Description:

Proposed New Mechanical
Ductwork & Fan Coil Unit
Layout Services.

First Floor Level

Drawn:	Scale:	Date:
D.J.Smith	1:50 @ A1	23-11-2018

Drawing Number:	Revision:
C10422-M-DW01	A